

environmental impacts associated with the proposed exemption.

Alternatives to the Proposed Action

Since the Commission concluded that there are no measurable environmental affects that would result from the proposed action, any alternatives with equal or greater environmental impacts need not be evaluated.

The principal alternative would be to deny the requested exemption. This would not reduce environmental impacts of plant operation and would result in reduced operational flexibility.

Alternate Use of Resources

This proposed action does not involve the use of any resources not previously considered in the Final Environmental Statements for the Peach Bottom Atomic Power Station, Units 2 and 3, dated April 1973.

Agencies and Persons Consulted

The staff consulted with the State of Pennsylvania regarding the environmental impact of the proposed action. The State Official had no comment.

Finding of No Significant Impact

The Commission has determined not to prepare an environmental impact statement for the proposed exemption.

Based upon the foregoing environmental assessment, the Commission concludes that the proposed action will not have a significant effect on the quality of the human environment.

For further details with respect to this action, see the application for exemption dated February 22, 1995, which is available for public inspection at the Commission's Public Document Room, the Gelman Building, 2120 L Street, NW., Washington, DC 20555, and at the local public document room located at Government Publications Section, State Library of Pennsylvania, (Regional Depository) Education Building, Walnut Street and Commonwealth Avenue, Box 1601, Harrisburg, Pennsylvania 17105.

Dated at Rockville, Maryland, this 14th day of April 1994.

For the Nuclear Regulatory Commission.

John F. Stolz,

Director, Project Directorate, I-2 Division of Reactor Projects—I/II, Office of Nuclear Reactor Regulation.

[FR Doc. 95-9893 Filed 4-20-95; 8:45 am]

BILLING CODE 7590-01-M

Nuclear Safety Research Review Committee Meetings of Subcommittee on Instrumentation and Control (I&C) and Human Factors and Subcommittee on Research in Support of Risk-Based Regulation (PRA Subcommittee)

AGENCY: Nuclear Regulatory Commission.

ACTION: Notice of meetings.

The NSRRC I&C and Human Factors Subcommittee will hold a meeting on May 18 and 19, 1995 and the PRA Subcommittee on May 19, 1995. A part of the May 19 meeting will be a joint meeting of the two subcommittees. The meetings will take place in Room T-2B3, Two White Flint North (TWFN) Building, 11545 Rockville Pike, Rockville, MD.

The meetings will be open to public attendance.

The I&C and Human Factors Subcommittee will review human factors research programs. In the joint meeting, the two subcommittees will jointly review research related to representation of human performance and organizational factors in probabilistic risk assessments. After the joint meeting, the PRA subcommittee will review NRC probabilistic risk assessment policy and practice in relation to research needs.

The agenda will be as follows:

Thursday, May 18: I&C and Human Factors Subcommittee

- 8:30-10:00 Introduction; overview of human factors research.
- 10:15-11:45 Human-system interface; safety-related operator actions.
- 1:00-3:45 Human performance data collection, Halden human error project, communications, simulator training; radiation therapy; staffing projects.
- 3:45-5:00 Subcommittee discussion.

Friday, May 19: Joint Meeting of Both Subcommittees

- 8:00-8:30 Introduction, background.
- 8:30-9:45 Organizational performance measures and methods to include organizational factors in PRA.
- 10:00-11:45 Human performance measures.
- 11:45-12:00 Subcommittees discussion.
- 12:00 I&C and Human Factors Subcommittee adjourns at the conclusion of the joint meeting.

Friday, May 19, continued: PRA Subcommittee

- 1:15-1:30 Introductory remarks.
- 1:30-4:00 Update on PRA Policy Statement and PRA Implementation Plan.
- 4:00-5:00 Subcommittee discussion.

The Subcommittees will report to the full Committee on the facts and analyses discussed at the meetings.

Detailed agenda will be made available at the meetings.

Oral statements may be presented by members of the public with the concurrence of the presiding Subcommittee Chairman; written statements will be accepted and made available to the Subcommittee. Questions may be asked only by members of the Committee and the staff. Persons desiring to make oral statements should notify the Nuclear Regulatory Commission staff member named below as far in advance as is practicable so that appropriate arrangements can be made.

During the initial portions of the meetings, the Subcommittees may exchange preliminary views regarding matters to be considered during the balance of the meeting. The Subcommittees will then hear presentations by and hold discussions with representatives of the NRC staff regarding this review.

Further information regarding topics to be discussed, the scheduling of sessions, whether the meetings have been canceled or rescheduled, and the Chairmen's ruling on requests for the opportunity to present oral statements and the time allotted therefore can be obtained by a prepaid telephone call to Mr. George Sege (telephone 301/415-6593) between 8:00 a.m. and 4:30 p.m. (EST). Persons planning to attend these meetings are urged to contact the above named individual one or two business days before the scheduled meeting to be advised of any changes in schedule, etc., that may have occurred.

Dated: April 13 1995.

George Sege,

Technical Assistant to the Director Office of Nuclear Regulatory Research.

[FR Doc. 95-9895 Filed 4-20-95; 8:45 am]

BILLING CODE 7590-01-M

[Docket No. 50-309]

Maine Yankee Atomic Power Company; Notice of Consideration of Issuance of Amendment to Facility Operating License, Proposed No Significant Hazards Consideration Determination, and Opportunity For a Hearing

The U.S. Nuclear Regulatory Commission (the Commission) is considering issuance of an amendment to Facility Operating License No. DPR-36 issued to Maine Yankee Atomic Power Company (the licensee) for operation of the Maine Yankee Atomic Power Station located in Lincoln County, Maine.

The proposed amendment would revise the Technical Specifications to allow the use of the Westinghouse Electric Corporation sleeving process for repairing steam generator tubes.

Before issuance of the proposed license amendment, the Commission will have made findings required by the Atomic Energy Act of 1954, as amended (the Act) and the Commission's regulations.