

the record of the meeting if received on or before October 1, 1995.

Signed at Washington, DC this 19th day of September, 1995.

Olena Berg,

Assistant Secretary, Pension and Welfare Benefits Administration.

[FR Doc. 95-23588 Filed 9-21-95; 8:45 am]

BILLING CODE 4510-29-M

NUCLEAR REGULATORY COMMISSION

[Docket Nos. 50-334 and 50-412]

Duquesne Light Company, Ohio Edison Company, Pennsylvania Power Company, the Cleveland Electric Illuminating Company, the Toledo Edison Company Beaver Valley Power Station, Unit Nos. 1 and 2; Notice of Consideration of Issuance of Amendments to Facility Operating Licenses, Proposed No Significant Hazards Consideration Determination, and Opportunity for a Hearing

The U.S. Nuclear Regulatory Commission (the Commission) is considering issuance of amendments to Facility Operating Licenses Nos. DPR-66 and NPF-73 Duquesne Light Company, et al. (the licensee) for operation of Beaver Valley Power Station, Unit Nos. 1 and 2 (BVPS-1 and BVPS-2), located in Beaver County, Pennsylvania.

The proposed amendments would revise the Administrative Controls section and the Bases section of the BVPS-1 and BVPS-2 technical specifications to be consistent with the requirements of the Offsite Dose Calculation Manual (ODCM). The ODCM was recently updated to reflect the radioactive liquid and gaseous effluent release limits and the liquid holdup tank activity limit of BVPS-1 License Amendment No. 188 and BVPS-2 License Amendment No. 70 which were issued June 12, 1995.

Before issuance of the proposed license amendments, the Commission will have made findings required by the Atomic Energy Act of 1954, as amended (the Act) and the Commission's regulations.

The Commission has made a proposed determination that the amendment requests involve no significant hazards consideration. Under the Commission's regulations in 10 CFR 50.92, this means that operation of the facility in accordance with the proposed amendments would not (1) involve a significant increase in the probability or consequences of an accident previously evaluated; or (2) create the possibility of

a new or different kind of accident from any accident previously evaluated; or (3) involve a significant reduction in a margin of safety. As required by 10 CFR 50.91(a), the licensee has provided its analysis of the issue of no significant hazards consideration, which is presented below:

1. Does the change involve a significant increase in the probability or consequences of an accident previously evaluated.

The likelihood that an accident will occur is neither increased or decreased by this proposed technical specification change which modifies the liquid and gaseous effluent release limits and the Liquid Holdup Tank activity limit. This technical specification change will not impact the function or method of operation of plant equipment. Thus, there is no significant increase in the probability of a previously analyzed accident due to this change. No systems, equipment, or components are affected by the proposed change. Thus, the consequences of a malfunction of equipment important to safety previously evaluated in the Updated Final Safety Analysis Report are not increased by this change.

The proposed change affects the liquid and gaseous effluent release limits and Liquid Holdup Tank activity limit. As such, the proposed change has no impact on accident initiators or plant equipment, and therefore, does not affect the probabilities or consequences of an accident.

Therefore, the proposed change will not involve a significant increase in the probability or consequences of an accident previously evaluated.

2. Does the change create the possibility of a new or different kind of accident from any accident previously evaluated?

The proposed technical specification revisions do not involve changes to the physical plant or operation of equipment considered as a potential accident initiator or equipment necessary to mitigate the consequences of an accident. The new Beaver Valley Power Station-Emergency Action Levels do use multiples of Offsite Dose Calculation Manual liquid release criteria for initiation of an unusual event or alert. However, there are no protective actions required when reaching either the unusual event or alert levels. The protective actions are performed when Environmental Protection Agency Drinking Water Standards are met or exceeded. Since limitations on concentrations of radioactive material released in liquid and gaseous effluents to unrestricted areas does not contribute to accident initiation, a change related to the requirement cannot produce a new accident scenario or produce a new type of equipment malfunction, as such, this change does not alter any existing accident scenarios.

Therefore, the proposed change does not create the possibility of a new or different kind of accident from any accident previously evaluated.

3. Does the change involve a significant reduction in a margin of safety?

The proposed change concerns the liquid and gaseous effluent release limits and Liquid Holdup Tank activity limit and does

not directly affect plant equipment or operation related to design basis accident prevention or mitigation. Safety limits and limiting safety system settings are not affected by this proposed change.

Therefore, use of the proposed technical specification would not involve a significant reduction in the margin of safety.

The NRC staff has reviewed the licensee's analysis and, based on this review, it appears that the three standards of 10 CFR 50.92(c) are satisfied. Therefore, the NRC staff proposes to determine that the amendment request involves no significant hazards consideration.

The Commission is seeking public comments on this proposed determination. Any comments received within 30 days after the date of publication of this notice will be considered in making any final determination.

Normally, the Commission will not issue the amendments until the expiration of the 30-day notice period. However, should circumstances change during the notice period such that failure to act in a timely way would result, for example, in derating or shutdown of the facility, the Commission may issue the license amendments before the expiration of the 30-day notice period, provided that its final determination is that the amendments involve no significant hazards consideration. The final determination will consider all public and State comments received. Should the Commission take this action, it will publish in the Federal Register a notice of issuance and provide for opportunity for a hearing after issuance. The Commission expects that the need to take this action will occur very infrequently.

Written comments may be submitted by mail to the Rules Review and Directives Branch, Division of Freedom of Information and Publications Services, Office of Administration, U.S. Nuclear Regulatory Commission, Washington, DC 20555, and should cite the publication date and page number of this Federal Register notice. Written comments may also be delivered to Room 6D22, Two White Flint North, 11545 Rockville Pike, Rockville, Maryland, from 7:30 a.m. to 4:15 p.m. Federal workdays. Copies of written comments received may be examined at the NRC Public Document Room, the Gelman Building, 2120 L Street, NW., Washington, DC.

The filing of requests for hearing and petitions for leave to intervene is discussed below.

By October 23, 1995, the licensee may file a request for a hearing with respect

to issuance of the amendments to the subject facility operating licenses and any person whose interest may be affected by this proceeding and who wishes to participate as a party in the proceeding must file a written request for a hearing and a petition for leave to intervene. Requests for a hearing and a petition for leave to intervene shall be filed in accordance with the Commission's "Rules of Practice for Domestic Licensing Proceedings" in 10 CFR Part 2. Interested persons should consult a current copy of 10 CFR 2.714 which is available at the Commission's Public Document Room, the Gelman Building, 2120 L Street, NW., Washington, DC, and at the local public document room located at the B. F. Jones Memorial Library, 663 Franklin Avenue, Aliquippa, Pennsylvania 15001. If a request for a hearing or petition for leave to intervene is filed by the above date, the Commission or an Atomic Safety and Licensing Board, designated by the Commission or by the Chairman of the Atomic Safety and Licensing Board Panel, will rule on the request and/or petition; and the Secretary or the designated Atomic Safety and Licensing Board will issue a notice of hearing or an appropriate order.

As required by 10 CFR 2.714, a petition for leave to intervene shall set forth with particularity the interest of the petitioner in the proceeding, and how that interest may be affected by the results of the proceeding. The petition should specifically explain the reasons why intervention should be permitted with particular reference to the following factors: (1) The nature of the petitioner's right under the Act to be made party to the proceeding; (2) the nature and extent of the petitioner's property, financial, or other interest in the proceeding; and (3) the possible effect of any order which may be entered in the proceeding on the petitioner's interest. The petition should also identify the specific aspect(s) of the subject matter of the proceeding as to which petitioner wishes to intervene. Any person who has filed a petition for leave to intervene or who has been admitted as a party may amend the petition without requesting leave of the Board up to 15 days prior to the first prehearing conference scheduled in the proceeding, but such an amended petition must satisfy the specificity requirements described above.

Not later than 15 days prior to the first prehearing conference scheduled in the proceeding, a petitioner shall file a supplement to the petition to intervene which must include a list of the contentions which are sought to be

litigated in the matter. Each contention must consist of a specific statement of the issue of law or fact to be raised or controverted. In addition, the petitioner shall provide a brief explanation of the bases of the contention and a concise statement of the alleged facts or expert opinion which support the contention and on which the petitioner intends to rely in proving the contention at the hearing. The petitioner must also provide references to those specific sources and documents of which the petitioner is aware and on which the petitioner intends to rely to establish those facts or expert opinion. Petitioner must provide sufficient information to show that a genuine dispute exists with the applicant on a material issue of law or fact. Contentions shall be limited to matters within the scope of the amendments under consideration. The contention must be one which, if proven, would entitle the petitioner to relief. A petitioner who fails to file such a supplement which satisfies these requirements with respect to at least one contention will not be permitted to participate as a party.

Those permitted to intervene become parties to the proceeding, subject to any limitations in the order granting leave to intervene, and have the opportunity to participate fully in the conduct of the hearing, including the opportunity to present evidence and cross-examine witnesses.

If a hearing is requested, the Commission will make a final determination on the issue of no significant hazards consideration. The final determination will serve to decide when the hearing is held.

If the final determination is that the amendments request involves no significant hazards consideration, the Commission may issue the amendments and make them immediately effective, notwithstanding the request for a hearing. Any hearing held would take place after issuance of the amendments.

If the final determination is that the amendments request involves a significant hazards consideration, any hearing held would take place before the issuance of the amendments.

A request for a hearing or a petition for leave to intervene must be filed with the Secretary of the Commission, U.S. Nuclear Regulatory Commission, Washington, DC 20555, Attention: Docketing and Services Branch, or may be delivered to the Commission's Public Document Room, the Gelman Building, 2120 L Street, NW., Washington, DC, by the above date. Where petitions are filed during the last 10 days of the notice period, it is requested that the petitioner promptly so inform the Commission by

a toll-free telephone call to Western Union at 1-(800) 248-5100 (in Missouri 1-(800) 342-6700). The Western Union operator should be given Datagram Identification Number N1023 and the following message addressed to John F. Stolz; Director, Project Directorate I-2: petitioner's name and telephone number, date petition was mailed, plant name, and publication date and page number of this Federal Register notice. A copy of the petition should also be sent to the Office of the General Counsel, U.S. Nuclear Regulatory Commission, Washington, DC 20555, and to Jay E. Silberg, Esquire, Shaw, Pittman, Potts & Trowbridge, 2300 N Street, NW., Washington, DC 20037, attorney for the licensee.

Nontimely filings of petitions for leave to intervene, amended petitions, supplemental petitions and/or requests for hearing will not be entertained absent a determination by the Commission, the presiding officer or the presiding Atomic Safety and Licensing Board that the petition and/or request should be granted based upon a balancing of the factors specified in 10 CFR 2.714(a)(1)(i)-(v) and 2.714(d).

For further details with respect to this action, see the application for amendment dated September 13, 1995, which is available for public inspection at the Commission's Public Document Room, the Gelman Building, 2120 L Street, NW., Washington, DC, and at the local public document room located at the B. F. Jones Memorial Library, 663 Franklin Avenue, Aliquippa, Pennsylvania 15001.

Dated at Rockville, Maryland, this 19th day of September 1995.

For the Nuclear Regulatory Commission,
Donald S. Brinkman,
Senior Project Manager Project Directorate I-2, Division of Reactor Projects—I/II, Office of Nuclear Reactor Regulation.

[FR Doc. 95-23540 Filed 9-21-95; 8:45 am]

BILLING CODE 7590-01-P

[Docket Nos. 50-445 AND 50-446]

**Texas Utilities Electric Company;
Environmental Assessment and
Finding of No Significant Impact**

The U.S. Nuclear Regulatory Commission (the Commission) is considering issuance of an exemption from certain requirements of its regulations to Facility Operating License No. NPF-87 and NPF-89, issued to the Texas Utilities Electric Company (TU Electric, the licensee), for operation of the Comanche Peak Steam Electric Station (CPSSES), Units 1 and 2, located in Somervell County, Texas.