

NATF form 82 will be used by researchers to request that NARA search for and make copies of pages of Federal population census schedules through the 1920 census. The NATF form 83 will be used by researchers to request that NARA search for and make copies of Eastern Cherokee applications of the U.S. Court of Claims, 1906-1909. Submission of requests on a form is necessary to handle in a timely fashion the volume of requests received for these records (approximately 10,000 per year for the NATF 81, approximately 1,400 per year for the NATF 82, and approximately 600 per year for the NATF 83) and the need to obtain specific information from the researcher to search for the records sought. The form will be printed on carbonless paper as a multi-part form to allow the researcher to retain a copy of his request and NARA to respond to the researcher on the results of the search or to bill for copies if the researcher wishes to order the copies. As a convenience, the form will allow researchers to provide credit card information to authorize billing and expedited mailing of the copies. NARA is not able at present to accept electronic submission of requests; however, we intend to address security of financial information and other issues as we continue our efforts to increase electronic access to NARA and its holdings.

Dated: May 21, 1998.

**L. Reynolds Cahoon,**

*Assistant Archivist for Human Resources and Information Services.*

[FR Doc. 98-14000 Filed 5-26-98; 8:45 am]

BILLING CODE 7515-01-P

---

**NATIONAL CREDIT UNION  
ADMINISTRATION**

**Sunshine Act Meeting; Notice of Meetings**

**TIME AND DATE:** 10:00 a.m., Thursday, May 28, 1998.

**PLACE:** Board Room, 7th Floor, Room 7047, 1775 Duke Street, Alexandria, VA 22314-3428.

**STATUS:** Open.

**MATTERS TO BE CONSIDERED:**

1. Requests from Two (2) Federal Credit Unions to Convert to Community Charters.

2. Request for a Corporate Federal Credit Union for a Field of Membership Amendment.

**RECESS:** 11:00 a.m.

**TIME AND DATE:** 11:30 a.m., Thursday, May 28, 1998.

**PLACE:** Board Room, 7th Floor, Room 7047, 1775 Duke Street, Alexandria, VA 22314-3428.

**STATUS:** Closed.

**MATTERS TO BE CONSIDERED:**

1. Administrative Action under Part 704 of NCUA's Rules and Regulations. Closed pursuant to exemption (8).

2. Corporate Credit Union Risk Rating system (CCURRS). Closed pursuant to exemption (8).

3. Administrative Action under Section 206 of the Federal Credit Union Act. Closed pursuant to exemptions (4), (5), (6), (7) and (8).

4. Six (6) Personnel Actions. Closed pursuant to exemptions (2) and (6).

5. Human Resources Delegations of Authority. Closed pursuant to exemptions (2) and (6).

**FOR FURTHER INFORMATION CONTACT:**

Becky Baker, Secretary of the Board, Telephone (703) 518-6304.

**Becky Baker,**

*Secretary of the Board.*

[FR Doc. 98-14077 Filed 5-22-98; 9:31 am]

BILLING CODE 7535-01-M

---

**NUCLEAR REGULATORY  
COMMISSION**

[Docket No. 50-220]

**Niagara Mohawk Power Corporation;  
Notice of Consideration of Issuance of  
Amendment to Facility Operating  
License, Proposed No Significant  
Hazards Consideration Determination,  
and Opportunity for a Hearing;  
Correction**

**AGENCY:** Nuclear Regulatory Commission.

**ACTION:** Notice; correction.

**SUMMARY:** This document corrects a notice appearing in the **Federal Register** on May 19, 1998 (63 FR 27601), that would change Technical Specifications 3/4.6.2, "Protective Instrumentation," to reflect modifications to the initiation instrumentation for the Control Room Air Treatment System. This action is necessary to correct an erroneous date.

**FOR FURTHER INFORMATION CONTACT:** David L. Meyer, Chief, Rules and Directives Branch, Division of Administrative Services, Office of Administration, telephone (301) 415-7162.

**SUPPLEMENTARY INFORMATION:** On page 27604, in the first column, in the third complete paragraph, on the first line, the date "June 1, 1998," should be corrected to read "June 18, 1998."

Dated at Rockville, Maryland, this 20th day of May 1998.

For the Nuclear Regulatory Commission.

**David L. Meyer,**

*Chief, Rules and Directives Branch, Division of Administrative Services, Office of Administration.*

[FR Doc. 98-13972 Filed 5-26-98; 8:45 am]

BILLING CODE 7590-01-P

---

**NUCLEAR REGULATORY  
COMMISSION**

[Docket Nos. 50-277 and 50-278]

**PECO Energy Company, Peach Bottom  
Atomic Power Station (Units 2 & 3);  
Confirmatory Order Modifying  
Licenses; Effective Immediately**

**I**

PECO Energy Company, (PECO or the Licensee) is the holder of Facility Operating Licenses Nos. DPR-44 and DPR-56, which authorize operation of Peach Bottom Atomic Power Station, Units 2 and 3, located in York County, Pennsylvania.

**II**

The staff of the U.S. Nuclear Regulatory Commission (NRC) has been concerned that Thermo-Lag 330-1 fire barrier systems installed by licensees may not provide the level of fire endurance intended and that licensees that use Thermo-Lag 330-1 fire barriers may not be meeting regulatory requirements. During the 1992 to 1994 time frame, the NRC staff issued Generic Letter (GL) 92-08, "Thermo-Lag 330-1 Fire Barriers" and subsequent requests for additional information that requested licensees to submit plans and schedules for resolving the Thermo-Lag issue. The NRC staff has obtained and reviewed all licensees' corrective plans and implementation schedules. The staff is concerned that some licensees may not be making adequate progress toward resolving the plant-specific issues, and that some implementation schedules may be either too tenuous or too protracted. For example, several licensees informed the NRC staff that their completion dates had slipped by 6 months to as much as 3 years. For plants that have completion action scheduled beyond 1997, the NRC staff has met with the licensees to discuss the progress of the licensees' corrective actions and the extent of licensee management attention regarding completion of Thermo-Lag corrective actions.

PECO Energy Company was one of the licensees with which the NRC staff held meetings. At these meetings, the NRC staff reviewed with PECO Energy Company the schedule of Thermo-Lag