

Place: Loyola University, Chicago, IL.
Contact Person: Dr. Michael Sokal,
 Program Director for Science and Technology
 Studies, National Science Foundation, 4201
 Wilson Boulevard, Arlington, VA 22230.
 Telephone: (703) 306-1742.

Agenda: To review and evaluate Science
 and Technology Studies proposals as part of
 the selection process for awards.

2. *Date & Time:* May 3-4, 1999; 8:30 a.m.-
 5:00 p.m.

Room: 310.

Contact Person: Dr. Cheryl L. Eavey,
 Program Director for Methods, Measurement
 and Statistics, National Science Foundation,
 4201 Wilson Boulevard, Arlington, VA
 22230. Telephone: (703) 306-1729.

Agenda: To review and evaluate Methods,
 Measurement and Statistics proposals as part
 of the selection process for awards.

3. *Date & Time:* May 6-7, 1999; 8:30 a.m.-
 5:00 p.m.

Room: 370.

Contact Person: Dr. Rachele Hollander,
 Program Director for Societal Dimensions of
 Engineering, Science and Technology,
 National Science Foundation, 4201 Wilson
 Boulevard, Arlington, VA 22230. Telephone:
 (703) 306-1743.

Agenda: To review and evaluate Societal
 Dimensions of Engineering, Science and
 Technology proposals as part of the selection
 process for awards.

Type of Meetings: Closed.

Purpose of Meeting: To provide advice and
 recommendations concerning support for
 research proposals submitted to the NSF for
 financial support.

Reason for Closing: The proposals being
 reviewed include information of a
 proprietary or confidential nature, including
 technical information; financial data, such as
 salaries; and personal information
 concerning individuals associated with the
 proposals. These matters are exempt under 5
 U.S.C. 552b(c)(4) and (6) of the Government
 in the Sunshine Act.

Dated: April 22, 1999.

Linda Allen-Benton,

*Acting Director, Division of Human Resource
 Management.*

[FR Doc. 99-10661 Filed 4-28-99; 8:45 am]

BILLING CODE 7555-01-M

NATIONAL SCIENCE FOUNDATION

Special Emphasis Panel in Physics; Notice of Meeting

In accordance with the Federal
 Advisory Committee Act (Pub. L. 92-
 463, as amended), the National Science
 Foundation announces the following
 meeting:

Name: Special Emphasis Panel in Physics
 (1208) DOE/NSF Nuclear Science Advisory
 Committee.

Date and Time: Friday, April 30, 1999; 9
 a.m. to 5 p.m.

Place: LBL Washington, DC Project Office;
 Suite 500, 1250 Maryland Ave, SW,
 Washington, DC.

Type of Meeting: Opened.

Contact Person: Dr. Bradley D. Keister,
 Program Director for Nuclear Physics, Room
 1015, National Science Foundation, 4201
 Wilson Blvd., Arlington, VA 22230.
 Telephone: (703) 306-1891.

Purpose of Meeting: To advise the National
 Science Foundation and the Department of
 Energy on scientific priorities within the
 field of basic nuclear science research.

Agenda:

- Presentation of Interim Report of the
 ISOL Task Force.
- Presentations by agencies
 representatives.
- Public Comment*.

Dated: April 22, 1999.

Linda Allen-Benton,

*Acting Director, Division of Human Resource
 Management.*

[FR Doc. 99-10664 Filed 4-28-99; 8:45 am]

BILLING CODE 7555-01-M

NUCLEAR REGULATORY COMMISSION

Indiana Michigan Power Company

[Docket Nos. 50-315 and 50-316]

Notice of Consideration of Issuance of Amendment to Facility Operating License, Proposed No Significant Hazards Consideration Determination, and Opportunity for a Hearing

The Nuclear Regulatory Commission
 (the Commission) is considering
 issuance of an amendment to Facility
 Operating License No. DPR-58 and
 Facility Operating License No. DPR-74
 issued to Indiana Michigan Power
 Company (the licensee) for operation of
 the Donald C. Cook Nuclear Power
 Plant, Units 1 and 2 located in Berrien
 County, Michigan.

The proposed license amendment
 would revise Technical Specification
 section 3/4.8.1.2, "Electrical Power
 Systems, Shutdown," and its associated
 bases to provide a one-time extension of
 the 18-month surveillance interval for
 specific surveillance requirements for
 Units 1 and 2. This surveillance will be
 performed prior to the first entry into
 Mode 4 subsequent to receipt of the
 requested T/S amendment. In addition,
 for Unit 2 only, a minor administrative
 change is included to delete a reference
 to T/S 4.0.8, which is no longer
 applicable. For Unit 1 only, an editorial
 change is made to add the word "or" to
 action statement 3.8.1.2.

Before issuance of the proposed
 license amendment, the Commission
 will have made findings required by the
 Atomic Energy Act of 1954, as amended

* Persons wishing to speak should make
 arrangement through the Contact Person identified
 above.

(the Act) and the Commission's
 regulations.

The Commission has made a
 proposed determination that the
 amendment request involves no
 significant hazards consideration. Under
 the Commission's regulations in 10 CFR
 50.92, this means that operation of the
 facility in accordance with the proposed
 amendment would not (1) Involve a
 significant increase in the probability or
 consequences of an accident previously
 evaluated; or (2) Create the possibility of
 a new or different kind of accident from
 any accident previously evaluated; or
 (3) Involve a significant reduction in a
 margin of safety. As required by 10 CFR
 50.91(a), the licensee has provided its
 analysis of the issue of no significant
 hazards consideration, which is
 presented below:

1. Does the Change Involve a Significant Increase in the Probability of Occurrence or Consequences of an Accident Previously Evaluated?

A discussion of each of the applicable
 accidents follows.

Fuel Handling Accident

The only time a fuel handling accident
 could occur is during the handling of a fuel
 assembly. The design of fuel handling
 equipment is such that an interruption of
 A.C. power would not cause a fuel element
 to be inadvertently dropped. Therefore, an
 interruption or loss of A.C. power does not
 significantly increase the probability of a fuel
 handling accident.

At present, fission product activities in the
 fuel assembly pellet-to-cladding gaps are
 greatly reduced. The fuel handling accident
 analysis considers the thyroid dose at the site
 boundary and in the low population zone.
 This dose is dominated by the isotope iodine
 131, which also decays more slowly than the
 other iodine contributors to the dose. The
 activity of iodine 131 decreases by one-half
 every 8.05 days. The current shutdown
 period of approximately 18 months
 represents over 70 half-lives. Activity of a
 radioactive material is generally considered
 to be negligible after 7 half-lives (a reduction
 in activity of $1/128$). By contrast, the accident
 analysis assumes an iodine reduction of less
 than $1/10$ (from activated charcoal filtration)
 in the fuel handling building, and no
 reduction in the containment, prior to
 release. Therefore, the consequences of a fuel
 handling accident are clearly bounded by the
 existing safety analysis without taking credit
 for any iodine removal by charcoal filtration.
 The greatly reduced fission product activity
 at the current time provides assurance that
 the consequences of this event are bounded
 by the existing analysis. Therefore, the
 consequences are not significantly increased.

Accidental Release of Radioactive Liquids

The inadvertent release of radioactive
 liquid wastes to the environment was
 evaluated for the waste evaporator
 condensate and monitor tanks, condensate
 storage tank, primary water storage tank,

refueling water storage tank (RWST), the auxiliary building storage tanks and the chemical and volume control system (CVCS) holdup tanks. It was concluded, in the UFSAR Chapter 14 evaluation, that loss of liquid from these tanks to the environment is not a credible accident. This conclusion does not depend on operating mode, hence, further evaluation of this event is not required.

Waste Gas Release

Radioactive gases are introduced into the reactor coolant by the escape of fission products if defects exist in the fuel cladding. The processing of the reactor coolant by auxiliary systems results in the accumulation of radioactive gases in various tanks. The two main sources of any significant gaseous radioactivity that could occur would be the volume control tank (VCT) and the gas decay tanks. It is assumed that a tank ruptures by an unspecified mechanism after the reactor has been operating for one core cycle with 1% defects in the fuel cladding. There is no identified mechanism by which an interruption or loss of power could result in a tank rupture. Therefore, it is concluded that the probability of occurrence of a tank rupture would not be significantly increased by an interruption or loss of A.C. power. The greatly reduced fission product activities at the current time provides assurance that the consequences of this event are bounded by the current analysis and would, therefore, not be significantly increased.

Uncontrolled Rod Cluster Control Assembly (RCCA) Withdrawal From a Subcritical Condition

This event can only occur with the reactor trip breakers closed and the control rod drive mechanisms (CRDMs) energized. With the exception of testing or special maintenance, the rod drive motor generator set remains tagged out until Mode 3 and this alone would preclude rod movement. If the conditions for rod withdrawal are met, two operable source range instruments and two reactor trip channels and trip breakers must be operable. An interruption or loss of power would preclude CRDM movement and release the control rods. The source range instruments would remain available. Therefore, it is concluded that the probability of occurrence of an uncontrolled RCCA withdrawal would not be significantly increased by an interruption or loss of A.C. power in Modes 5 or 6. Acceptable consequences for this event rely on precluding its occurrence.

Uncontrolled Boron Dilution

This event requires a malfunction of the CVCS. The CVCS is designed to limit, even under various postulated failure modes, the potential rate of dilution to a value which provides the operator sufficient time to correct the situation in a safe and orderly manner. The rate of addition of unborated water makeup to the reactor coolant system is limited by the capacity of the primary water pumps. The maximum addition rate in this case is 225 gpm with both primary water pumps running. An interruption or loss of A.C. power would preclude pump operation and accidental dilution. The RWST is not a credible dilution source as recognized by a

footnote to T/S 3/4.8.1.2. Therefore, the possibility of an uncontrolled boron dilution is not significantly increased. Acceptable consequences for this event rely on precluding its occurrence and by detection with the source range nuclear instrumentation required by the T/S in Modes 5 and 6.

The proposed revision involves deferral of certain surveillance requirements when shut down but does not reduce the required operable power sources of the Limiting Condition for Operation (LCO), does not increase the allowed outage time of any required operable power supplies and does not reduce the requirement to know that the deferred SRs [surveillance requirements] could be met at all times. Deferral of the testing does not by itself increase the potential that the testing would not be met and the previously evaluated accidents described above do not rely on automatic starting or loading of the single operable EDG [emergency diesel generator] permitted in Modes 5 and 6. The monthly EDG starts, fuel level checks, and fuel transfer pump checks will continue to be performed to provide adequate confidence that the required EDG will be available if needed. Therefore, it is concluded that the required A.C. sources will remain available and the previously evaluated consequences will not be increased.

The proposed administrative change for unit 2 deletes a reference to T/S 4.0.8 that is no longer applicable and, thus, does not increase the probability or consequences of an accident. The editorial change to unit 1 corrects a typographical error. The correction is not intended to change the meaning.

Therefore, based on the above discussion, it is concluded that the proposed amendment does not involve a significant increase in the probability or consequences of an accident previously evaluated.

2. Does the Change Create the Possibility of a New or Different Kind of Accident From Any Accident Previously Evaluated?

The proposed changes do not involve operation of the required electrical power sources in a manner or configuration different than those previously recognized or evaluated. No new failure mechanisms of the A.C. power supplies are introduced by extension of the subject surveillance intervals.

The proposed administrative change for unit 2 deletes a reference to T/S 4.0.8 that is no longer applicable and, thus, does not create the possibility of a new or different kind of accident. The editorial change to unit 1 corrects a typographical error. The correction is not intended to change the meaning. Therefore, it is concluded that the proposed changes do not create the possibility of a new or different kind of accident from any previously evaluated.

3. Does the Change Involve a Significant Reduction in a Margin of Safety?

The required operable power supplies have not been reduced. Deferral of the specified SRs does not by itself introduce a failure mechanism, and past performance of the SRs has demonstrated reliability in passing the

deferred surveillances. Therefore, the availability of power supplies assumed for accident mitigation is not significantly reduced and previous margins of safety are maintained.

The proposed administrative change for unit 2 deletes a reference to T/S 4.0.8 that is no longer applicable and thus, does not increase the probability or consequences of an accident. The editorial change to unit 1 corrects a typographical error. The correction is not intended to change the meaning. Therefore, these changes do not involve a significant reduction in the margin of safety.

In summary, based upon the above evaluation, I&M has concluded that these changes involve no significant hazards consideration.

The NRC staff has reviewed the licensee's analysis and, based on this review, it appears that the three standards of 10 CFR 50.92 are satisfied. Therefore, the NRC staff proposes to determine that the amendment request involves no significant hazards consideration.

The Commission is seeking public comments on this proposed determination. Any comments received within 30 days after the date of publication of this notice will be considered in making any final determination.

Normally, the Commission will not issue the amendment until the expiration of the 30-day notice period. However, should circumstances change during the notice period such that failure to act in a timely way would result, for example, in derating or shutdown of the facility, the Commission may issue the license amendment before the expiration of the 30-day notice period, provided that its final determination is that the amendment involves no significant hazards consideration. The final determination will consider all public and State comments received. Should the Commission take this action, it will publish in the **Federal Register** a notice of issuance and provide for opportunity for a hearing after issuance. The Commission expects that the need to take this action will occur very infrequently.

Written comments may be submitted by mail to the Chief, Rules and Directives Branch, Division of Administrative Services, Office of Administration, U.S. Nuclear Regulatory Commission, Washington, DC 20555-0001, and should cite the publication date and page number of this **Federal Register** notice. Written comments may also be delivered to Room 6D59, Two White Flint North, 11545 Rockville Pike, Rockville, Maryland, from 7:30 a.m. to 4:15 p.m. Federal workdays. Copies of written comments received

may be examined at the NRC Public Document Room, the Gelman Building, 2120 L Street, NW., Washington, DC.

The filing of requests for hearing and petitions for leave to intervene is discussed below.

By May 26, 1999, the licensee may file a request for a hearing with respect to issuance of the amendment to the subject facility operating license and any person whose interest may be affected by this proceeding and who wishes to participate as a party in the proceeding must file a written request for a hearing and a petition for leave to intervene. Requests for a hearing and a petition for leave to intervene shall be filed in accordance with the Commission's "Rules of Practice for Domestic Licensing Proceedings" in 10 CFR Part 2. Interested persons should consult a current copy of 10 CFR 2.714 which is available at the Commission's Public Document Room, the Gelman Building, 2120 L Street, NW, Washington, DC, and at the local public document room located at the Maud Preston Palenske Memorial Library, 500 Market Street, St. Joseph, MI 49085. If a request for a hearing or petition for leave to intervene is filed by the above date, the Commission or an Atomic Safety and Licensing Board, designated by the Commission or by the Chairman of the Atomic Safety and Licensing Board Panel, will rule on the request and/or petition; and the Secretary or the designated Atomic Safety and Licensing Board will issue a notice of hearing or an appropriate order.

As required by 10 CFR 2.714, a petition for leave to intervene shall set forth with particularity the interest of the petitioner in the proceeding, and how that interest may be affected by the results of the proceeding. The petition should specifically explain the reasons why intervention should be permitted with particular reference to the following factors: (1) The nature of the petitioner's right under the Act to be made party to the proceeding; (2) the nature and extent of the petitioner's property, financial, or other interest in the proceeding; and (3) the possible effect of any order which may be entered in the proceeding on the petitioner's interest. The petition should also identify the specific aspect(s) of the subject matter of the proceeding as to which petitioner wishes to intervene. Any person who has filed a petition for leave to intervene or who has been admitted as a party may amend the petition without requesting leave of the Board up to 15 days prior to the first prehearing conference scheduled in the proceeding, but such an amended

petition must satisfy the specificity requirements described above.

Not later than 15 days prior to the first prehearing conference scheduled in the proceeding, a petitioner shall file a supplement to the petition to intervene which must include a list of the contentions which are sought to be litigated in the matter. Each contention must consist of a specific statement of the issue of law or fact to be raised or controverted. In addition, the petitioner shall provide a brief explanation of the bases of the contention and a concise statement of the alleged facts or expert opinion which support the contention and on which the petitioner intends to rely in proving the contention at the hearing. The petitioner must also provide references to those specific sources and documents of which the petitioner is aware and on which the petitioner intends to rely to establish those facts or expert opinion. Petitioner must provide sufficient information to show that a genuine dispute exists with the applicant on a material issue of law or fact. Contentions shall be limited to matters within the scope of the amendment under consideration. The contention must be one which, if proven, would entitle the petitioner to relief. A petitioner who fails to file such a supplement which satisfies these requirements with respect to at least one contention will not be permitted to participate as a party.

Those permitted to intervene become parties to the proceeding, subject to any limitations in the order granting leave to intervene, and have the opportunity to participate fully in the conduct of the hearing, including the opportunity to present evidence and cross-examine witnesses.

If a hearing is requested, the Commission will make a final determination on the issue of no significant hazards consideration. The final determination will serve to decide when the hearing is held.

If the final determination is that the amendment request involves no significant hazards consideration, the Commission may issue the amendment and make it immediately effective, notwithstanding the request for a hearing. Any hearing held would take place after issuance of the amendment.

If the final determination is that the amendment request involves a significant hazards consideration, any hearing held would take place before the issuance of any amendment.

A request for a hearing or a petition for leave to intervene must be filed with the Secretary of the Commission, U.S. Nuclear Regulatory Commission, Washington, DC 20555-0001, Attention:

Rulemakings and Adjudications Staff, or may be delivered to the Commission's Public Document Room, the Gelman Building, 2120 L Street, NW., Washington, DC, by the above date. A copy of the petition should also be sent to the Office of the General Counsel, U.S. Nuclear Regulatory Commission, Washington, DC 20555-0001, and to Jeremy J. Euto, Esquire, 500 Circle Drive, Buchanan, MI 49107, attorney for the licensee.

Nontimely filings of petitions for leave to intervene, amended petitions, supplemental petitions and/or requests for hearing will not be entertained absent a determination by the Commission, the presiding officer or the presiding Atomic Safety and Licensing Board that the petition and/or request should be granted based upon a balancing of the factors specified in 10 CFR 2.714(a)(1)(I)-(v) and 2.714(d).

For further details with respect to this action, see the application for amendment dated December 3, 1998, which is available for public inspection at the Commission's Public Document Room, the Gelman Building, 2120 L Street, NW., Washington, DC, and at the local public document room located at the Maud Preston Palenske Memorial Library, 500 Market Street, St. Joseph, MI 49085.

Dated at Rockville, Maryland, this 22nd day of April 1999.

For the Nuclear Regulatory Commission.

John F. Stang, Sr.,

Project Manager, Section 1, Project Directorate III, Division of Licensing Project Management, Office of Nuclear Reactor Regulation.

[FR Doc. 99-10687 Filed 4-28-99; 8:45 am]

BILLING CODE 7590-01-P

NUCLEAR REGULATORY COMMISSION

[Docket Nos. 50-282 and 50-306]

Northern States Power Company; Notice of Consideration of Issuance of Amendments to Facility Operating Licenses DPR-42 and DPR-60 Proposed No Significant Hazards Consideration Determination, and Opportunity for a Hearing

The U.S. Nuclear Regulatory Commission (the Commission) is considering issuance of amendments to Facility Operating Licenses DPR-42 and DPR-60 issued to Northern States Power Company (the licensee) for operation of the Prairie Island Nuclear Generating Plant, Units 1 and 2, located in Goodhue County, Minnesota.

The proposed amendments would change the implementation date for the