

Dated: October 31, 2000.

Karen J. York,

Committee Management Officer.

[FR Doc. 00-28403 Filed 11-3-00; 8:45 am]

BILLING CODE 7555-01-M

NATIONAL SCIENCE FOUNDATION

Special Emphasis Panel in Mathematical Sciences; Notice of Meeting

In accordance with the Federal Advisory Committee Act (Pub. L. 92-463, as amended), the National Science Foundation announces the following meeting.

Name and Committee Code: Special Emphasis in Mathematical Sciences (1204).

Date and Time: November, 29-December 1, 2000; 8:30 a.m. until 5 p.m.

Place: Room 320, 330, & 360, National Science Foundation, 4201 Wilson Boulevard, Arlington, VA 22230.

Type of Meeting: Closed.

Contact Person: Drs. Henry Warchall, Deborah F. Lockhart, Benjamin M. Mann, John Stufken, and Joe Jenkins, Program Director, National Science Foundation, 4201 Wilson Boulevard, Arlington, VA 22230. Telephone: (703) 292-8870.

Purpose of Meeting: To provide advice and recommendations concerning proposal submitted to NSF for financial support.

Agenda: To review and evaluate proposals concerning the Fluid Dynamics Panel, as part of the selection process for awards.

Reason for Closing: The proposals being reviewed include information of a proprietary or confidential nature, including technical information; financial data, such as salaries and personal information concerning individuals associated with the proposals. These matters are exempt under 5 U.S.C. 552b(c)(4) and (6) of the Government in the Sunshine Act.

Dated: October 31, 2000.

Karen J. York,

Committee Manager Officer.

[FR Doc. 00-28397 Filed 11-3-00; 8:45 am]

BILLING CODE 7555-01-M

NATIONAL SCIENCE FOUNDATION

Special Emphasis Panel in Physics; Notice of Meeting

In accordance with the Federal Advisory Committee Act (Pub. L. 92-463, as amended), the National Science Foundation announces the following meetings of the Special Emphasis Panel in Physics (1208):

Date/Time: December 5, 2000; 8 a.m.-6 p.m.

Place: State University of New York at Stony Brook.

Contact Person: Dr. Bradley D. Keister, Program Director for Nuclear, Division of Physics, National Science Foundation, 4201

Wilson Boulevard, Room 1015, Arlington, VA 22230. Telephone: (703) 292-7377,

Purpose of Meeting: To review the scientific program of the nuclear physics laboratory and experimental group at SUNY Stony Brook.

Date/Time: December 18-19, 2000; 8 a.m.-6 p.m.

Place: Indiana University Cyclotron Facility, Indiana University.

Contact Person: Dr. Bradley D. Keister, Program Director for Nuclear Physics, Division of Physics, National Science Foundation, 4201 Wilson Boulevard, Room 1015, Arlington, VA 22230. Telephone: (703) 292-7377.

Purpose of Meeting: To review the scientific program of the nuclear physics experimental group at Indiana University.

Date/Time: January 8-10, 2001; 8 a.m.-5:30 p.m.

Place: National Science Foundation, 4201 Wilson Blvd., Room 320, Arlington, VA.

Contact Person: Dr. Bradley D. Keister, Program Director for Nuclear Physics, Division of Physics, National Science Foundation, 4201 Wilson Boulevard, Room 1015, Arlington, VA 22230. Telephone: (703) 292-7377.

Purpose of Meeting: To provide advice and recommendations concerning proposals submitted to the Nuclear Physics Program for financial support.

Agenda: To review and evaluate proposals as part of the selection process for awards.

Reason for Closings: The proposals being reviewed include information of a proprietary or confidential nature, including technical information, financial data, such as salaries; and personal information concerning individuals associated with the proposals. These matters are exempt under 5 U.S.C. 552b(c), (4) and (6) of the Government in the Sunshine Act.

Dated: October 31, 2000.

Karen J. York,

Committee Management Officer.

[FR Doc. 00-28405 Filed 11-3-00; 8:45 am]

BILLING CODE 7555-01-M

NATIONAL SCIENCE FOUNDATION

Special Emphasis Panel in Social, Behavioral and Economic Sciences; Notice of Meeting

In accordance with the Federal Advisory Committee Act (Pub. L. 92-463, as amended), the National Science Foundation announces the following meeting:

Name: Special Emphasis Panel in Social, Behavioral, and Economic Sciences (#1766).

Date/Time: January 4-5, 2001; 8 a.m. to 5 p.m.

Place: National Science Foundation, 4201 Wilson Blvd., Rooms 360, 3365, and 360, Arlington, VA.

Type of Meeting: Closed.

Contact Person: Ms. Susan Parris, Program Manager, International Research Fellowship Program, Division of International Programs,

National Science Foundation, 4201 Wilson Boulevard, Room 935, Arlington, VA 22230, (703) 306-1711.

Purpose of Meeting: To provide advice and recommendations concerning proposals submitted to the National Science Foundation for financial support.

Agenda: To review and evaluate applications to the International Research Fellowship Program submitted in response to the program announcement (NSF 00141).

Reason for Closing: The proposals being reviewed include information of a proprietary or confidential nature, including technical information, financial data such as salaries, and personal information concerning individuals associated with the proposals. These matters are exempt under 5 U.S.C. 552b(c), (4) and (6) of the Government in the Sunshine Act.

Dated: October 31, 2000.

Karen J. York,

Committee Management Officer.

[FR Doc. 00-28406 Filed 11-3-00; 8:45 am]

BILLING CODE 7555-01-M

NUCLEAR REGULATORY COMMISSION

Agency Information Collection Activities: Proposed Collection; Comment Request

AGENCY: U. S. Nuclear Regulatory Commission, (NRC).

ACTION: Notice of pending NRC action to submit an information collection request to OMB and solicitation of public comment.

SUMMARY: The NRC is preparing a submittal to OMB for review of continued approval of information collections under the provisions of the Paperwork Reduction Act of 1995 (44 U.S.C. Chapter 35).

Information Pertaining to the Requirement to be Submitted:

1. *The title of the information collection:* 10 CFR Part 95—Facility Security Clearance and Safeguarding of National Security Information and Restricted Data.

2. *Current OMB approval number:* None.

3. *How often the collection is required:* On occasion.

4. *Who is required or asked to report:* NRC-regulated facilities and other organizations requiring access to NRC-classified information.

5. *The number of annual respondents:* 8.

6. *The number of hours needed annually to complete the requirement or request:* 443.

7. *Abstract:* NRC-regulated facilities and other organizations are required to provide information and maintain

records to ensure that an adequate level of protection is provided to NRC-classified information and material.

Submit, by January 5, 2001, comments that address the following questions:

1. Is the proposed collection of information necessary for the NRC to properly perform its functions? Does the information have practical utility?

2. Is the burden estimate accurate?

3. Is there a way to enhance the quality, utility, and clarity of the information to be collected?

4. How can the burden of the information collection be minimized, including the use of automated collection techniques or other forms of information technology?

A copy of the draft supporting statement may be viewed free of charge at the NRC Public Document Room, One White Flint North, 11555 Rockville Pike, Room O-1F23, Rockville, MD 20852. OMB clearance requests are available at the NRC worldwide web site: <http://www.nrc.gov/NRC/PUBLIC/OMB/index.html>. The document will be available on the NRC home page site for 60 days after the signature date of this notice.

Comments and questions about the information collection requirements may be directed to the NRC Clearance Officer, Brenda Jo. Shelton, U.S. Nuclear Regulatory Commission, T-6 E6, Washington, DC 20555-0001, by telephone at 301-415-7233, or by Internet electronic mail at BJS1@NRC.GOV.

Dated at Rockville, Maryland, this 30th day of October, 2000.

For the Nuclear Regulatory Commission.

Brenda Jo. Shelton,

NRC Clearance Officer, Office of the Chief Information Officer.

[FR Doc. 00-28357 Filed 11-3-00; 8:45 am]

BILLING CODE 7590-01-P

NUCLEAR REGULATORY COMMISSION

[Docket No. 50-461]

In the Matter of Amergen Energy Company, LLC (Clinton Power Station); Exemption

I

AmerGen Energy Company, LLC (AmerGen, the licensee) is the holder of Facility Operating License No. NPF-62 which authorizes operation of the Clinton Power Station (CPS). The license provides, among other things, that the facility is subject to all rules, regulations, and orders of the U.S. Nuclear Regulatory Commission (the Commission) now or hereafter in effect.

The facility consists of a boiling water reactor located on the licensee's CPS site in DeWitt County, Illinois.

II

The U.S. Nuclear Regulatory Commission (NRC) has established requirements in Appendix G of Part 50 to Title 10, Code of Federal Regulations (10 CFR Part 50, Appendix G), to protect the integrity of the reactor coolant pressure boundary in nuclear power plants. This Appendix to Part 50 requires the pressure-temperature (P-T) limits for an operating plant to be at least as conservative as those that would be generated if the methods of Appendix G to Section XI of the American Society of Mechanical Engineers Boiler and Pressure Vessel Code (Appendix G to the Code) were applied. The methodology of Appendix G to the Code postulates the existence of a sharp surface flaw in the reactor pressure vessel (RPV) that is normal to the direction of the maximum applied stress. For materials in the beltline and upper and lower head regions of the RPV, the maximum flaw size is postulated to have a depth that is equal to one-fourth of the thickness and a length equal to 1.5 times the thickness. For the case of evaluating RPV nozzles, the surface flaw is postulated to propagate parallel to the axis of the nozzle's corner radius. The basic parameter in Appendix G to the Code for calculating P-T limit curves is the stress intensity factor, K_I , which is a function of the stress state and flaw configuration. The methodology requires that licensees determine the reference stress intensity (K_{Ia}) factors, which vary as a function of temperature, from the reactor coolant system (RCS) operating temperatures, and from the adjusted reference temperatures (ARTs) for the limiting materials in the RPV. Thus, the critical locations in the RPV beltline and head regions are the $1/4$ -thickness ($1/4T$) and $3/4$ -thickness ($3/4T$) locations, which correspond to the points of the crack tips if the flaws are initiated and grown from the inside and outside surfaces of the vessel, respectively. Regulatory Guide (RG) 1.99, Revision 2, provides an acceptable method of calculating ARTs for ferritic RPV materials; the methods of RG 1.99, Revision 2, include methods for adjusting the ARTs of materials in the beltline region of the RPV, where the effects of neutron irradiation may induce an increased level of embrittlement in the materials.

The methodology of Appendix G requires that P-T curves must satisfy a safety factor of 2.0 on primary membrane and bending stresses during

normal plant operations (including heatups, cooldowns, and transient operating conditions), and a safety factor of 1.5 on primary membrane and bending stresses when leak rate or hydrostatic pressure tests are performed on the RCS. Table 1 to 10 CFR Part 50, Appendix G, provides the staff's criteria for meeting the P-T limit requirements of Appendix G to the Code and 10 CFR Part 50, Appendix G.

By letter dated August 25, 2000, as supplemented September 21, October 14, and October 25, 2000, AmerGen submitted a license amendment request to update the P-T limit curves for CPS. In the submittals, AmerGen also requested NRC approval for exemptions to use Code Cases N-588 and N-640 as methods that would allow AmerGen to deviate from complying with the requirements in 10 CFR Part 50, Appendix G, for generating the P-T limit curves.

Code Case N-588

AmerGen has requested, pursuant to 10 CFR 50.60(b), an exemption to use Code Case N-588 as the basis for evaluating the axial and circumferential welds in the CPS RPV. The current methods of appendix G to the Code mandate consideration of an axial flaw in full penetration RPV welds, and thus, for circumferential welds, dictate that the flaw be oriented transverse to the axis of the weld. Postulation of an axial flaw in a circumferential weld is unrealistic because the length of the flaw would extend well beyond the girth of the circumferential weld and into the adjoining base metal material. Industry experience with the repair of weld indications found during preservice inspection, and data taken from destructive examination of actual vessel welds, confirms that any remaining flaws are small, laminar in nature, and do not transverse the weld bead orientation. Therefore, any potential defects introduced during the fabrication process, and not detected during subsequent nondestructive examinations, would only be expected to be oriented in the direction of weld fabrication. For circumferential RPV welds, the methods of the Code Case therefore postulate the presence of a flaw that is oriented in a direction parallel to the axis of the weld (*i.e.*, in a circumferential orientation).

An analysis provided to the American Society of Mechanical Engineers (ASME) Code's Working Group on Operating Plant Criteria (WGOPC) (in which Code Case N-588 was developed) indicated that if an axial flaw is postulated on a circumferential weld, then based on the correction factors for