

**NUCLEAR REGULATORY
COMMISSION**

[Docket 72-16]

**Environmental Assessment and
Finding of No Significant Impact
Related to Virginia Electric and Power
Company's Proposed Amendment to
License No. SNM-2507**

The U.S. Nuclear Regulatory Commission (NRC or Commission) is considering issuance of an amendment, pursuant to 10 CFR 72.56, to Special Nuclear Material License No. 2507 (SNM-2507) held by Virginia Electric and Power Company (Dominion) for the North Anna independent spent fuel storage installation (ISFSI). The requested amendment would revise the Technical Specifications (TS) of SNM-2507 to specifically permit the use of the TN-32 storage cask to store spent fuel with a higher initial enrichment and burnup than currently specified in the TS for the North Anna ISFSI. An environmental assessment (EA) was performed by the NRC staff in support of its review of the license amendment request, in accordance with the requirements of 10 CFR part 51. The conclusion of the EA is a Finding of No Significant Impact (FONSI).

Environmental Assessment

Identification of Proposed Action: By letter dated May 28, 2002, as supplemented, Dominion requested an amendment to revise the TS of SNM-2507 for the North Anna ISFSI. The changes would specifically permit the use of the TN-32 storage cask to store spent fuel with a higher initial enrichment and burnup than currently specified in the TS. Currently, the TS for the North Anna ISFSI limit the fuel to be stored in the TN-32 to the following: initial enrichment of $\leq 3.85\%$ (wt U-235), assembly average burnup of $\leq 40,000$ MWD/MTU, and heat generation of ≤ 0.847 Kw/assembly. This amendment requests the limits be amended as follows: initial enrichment of $\leq 4.35\%$ (wt U-235), assembly average burnup $\leq 45,000$ MWD/MTU, and heat generation of ≤ 1.02 Kw/assembly.

Need for the Proposed Action: The proposed action is necessary to allow continued storage of spent fuel in dry casks at the North Anna ISFSI. Without this amendment, North Anna will be unable to load spent fuel in TN-32 casks because the remaining spent fuel at the site has the higher enrichment and burnup. If unable to store spent fuel in TN-32 casks, North Anna will not be able to retain full core offload capability. North Anna would

eventually have to find an alternate means to store fuel, or shut down.

Environmental Impacts of the Proposed Action: The NRC has completed its evaluation of the proposed action and concludes that granting the request for amendment to allow the storage of spent fuel assemblies with burnup and initial enrichment of up to 45,000 MWD/MTU and 4.35% (wt U-235), respectively, in TN-32 casks used at the North Anna ISFSI, will not increase the probability or consequence of accidents beyond that bounded by previous analysis. No changes are being made in the types of any effluents that may be released offsite. With regard to radiological impacts, the addition of higher burnup and initial enrichment spent fuel assemblies was calculated to yield an average surface dose rate of 218 mrem/hour at the TN-32 cask side surface. A re-evaluation of occupational doses based on actual operating experience and the revised surface dose rate, indicates that the overall exposure to workers during cask loading, transport, and emplacement will increase from the original estimate of 7.19 person-rem to 14.30 person-rem. The dose to the nearest permanent resident due to ISFSI operations was calculated to be 2.10 mrem/yr. If the proposed amendment is approved, the total annual dose for all site sources (ISFSI, Unit 1 and Unit 2) would be 5.10 mrem/yr. This is well below the 25 mrem/yr limit cited in 10 CFR 72.104(a). Based on the occupational and public dose analysis results, there are no significant radiological environmental impacts associated with the proposed action.

The amendment only affects the requirements associated with the contents of the casks and does not affect non-radiological plant effluents or any other aspects of the environment. Therefore, there are no significant non-radiological environmental impacts associated with the proposed action.

Accordingly, the Commission concludes that there are no significant environmental impacts associated with the proposed action.

Environmental Impact of the Alternative to the Proposed Action: The alternative to the proposed action would be to deny the request for amendment (i.e., the "no-action" alternative). Denial of the proposed action would result in North Anna having to store its remaining spent fuel in the spent fuel pool. Without dry cask storage, North Anna would lose the capability to maintain full core offload and eventually both units would have to shut down due to lack of storage space. The electrical generating capacity lost

would have to be replaced by another source of power, which could result in greater environmental impact and/or higher electricity rates for customers. Increased storage in the spent fuel pool could potentially lead to greater occupational exposure than dry cask storage due to the proximity of workers to the fuel. The environmental impacts of the alternative action could be greater than the proposed action.

Given that the alternative action of denying the approval for the amendment has no lesser environmental impacts associated with it, the Commission concludes that the preferred alternative is to grant this amendment.

Agencies and Persons Consulted and Sources Used: On April 9, 2003, Mr. Les Foldese of the Virginia Department of Health, Radiological Health Programs, was contacted regarding the proposed action and had no concerns. The NRC staff have determined that the proposed amendment will not introduce any new effects on listed species, critical habitat, or historical properties. Therefore no further consultation is required. 10 CFR part 51 was used as a source.

Finding of No Significant Impact

The environmental impacts of the proposed action have been reviewed in accordance with the requirements set forth in 10 CFR part 51. Based upon the foregoing Environmental Assessment, the Commission finds that the proposed action of granting an amendment to permit the use of the TN-32 dry storage casks to store spent fuel with a higher initial enrichment ($\leq 4.35\%$ wt U-235) and burnup ($\leq 45,000$ MWD/MTU) at the North Anna ISFSI will not significantly impact the quality of the human environment. Accordingly, the Commission has determined not to prepare an environmental impact statement for the proposed amendment.

The request for the amendment was docketed under 10 CFR part 72, Docket 72-16. For further details with respect to this action, see the amendment application dated May 28, 2002, as supplemented, which is available for public inspection at the Commission's Public Document Room, One White Flint North Building, 11555 Rockville Pike, Rockville, MD or from the publicly available records component of NRC's Agencywide Documents Access and Management System (ADAMS). The NRC maintains ADAMS, which provides text and image files of NRC's public documents. These documents may be accessed through the NRC's Public Electronic Reading Room on the Internet at <http://www.nrc.gov/reading-rm/adams.html>.

If you do not have access to ADAMS, or if there are problems in accessing the documents located in ADAMS, contact the NRC Public Document Room Reference staff at 1-800-397-4209, 301-415-4737, or by e-mail to pdr@nrc.gov.

Dated at Rockville, Maryland, this 2nd day of June, 2003.

For the Nuclear Regulatory Commission.

Mary Jane Ross-Lee,

Senior Project Manager, Spent Fuel Project Office, Office of Nuclear Material Safety and Safeguards.

[FR Doc. 03-14683 Filed 6-10-03; 8:45 am]

BILLING CODE 7590-01-P

NUCLEAR REGULATORY COMMISSION

Regulatory Guide; Issuance, Availability

The Nuclear Regulatory Commission (NRC) has issued a revision of a guide in its Regulatory Guide Series. This series has been developed to describe and make available to the public such information as methods acceptable to the NRC staff for implementing specific parts of the NRC's regulations, techniques used by the staff in its review of applications for permits and licenses, and data needed by the NRC staff in its review of applications for permits and licenses.

Regulatory Guide 1.194, "Atmospheric Relative Concentrations for Control Room Radiological Habitability Assessments at Nuclear Power Plants," provides guidance on determining atmospheric relative concentration (x/Q) values in support of design basis control room radiological habitability assessments at nuclear power plants.

Comments and suggestions in connection with items for inclusion in guides currently being developed or improvements in all published guides are encouraged at any time. Written comments may be submitted to the Rules and Directives Branch, Division of Administrative Services, Office of Administration, U.S. Nuclear Regulatory Commission, Washington DC 20555.

Regulatory Guides are available for inspection or downloading at the NRC's Web site at <http://www.nrc.gov> under Regulatory Guides and in NRC's Electronic Reading Room (ADAMS System) at the same site. Single copies of regulatory guides may be obtained free of charge by writing the Reproduction and Distribution Services Section, U.S. Nuclear Regulatory Commission, Washington, DC 20555-0001, or by fax to (301) 415-2289, or by e-mail to distribution@nrc.gov. Issued

guides may also be purchased from the National Technical Information Service (NTIS) on a standing order basis. Details on this service may be obtained by writing NTIS at 5285 Port Royal Road, Springfield, VA 22161; <http://www.ntis.gov/>; telephone 1-800-553-6847. Regulatory guides are not copyrighted, and Commission approval is not required to reproduce them. (5 U.S.C. 552(a))

Dated at Rockville, MD this 30th day of May 2003.

For the Nuclear Regulatory Commission.

Ashok C. Thadani,

Director, Office of Nuclear Regulatory Research.

[FR Doc. 03-14684 Filed 6-10-03; 8:45 am]

BILLING CODE 7590-01-P

NUCLEAR REGULATORY COMMISSION

Regulatory Guide; Issuance, Availability

The Nuclear Regulatory Commission (NRC) has issued three guides in its Regulatory Guide Series. This series has been developed to describe and make available to the public such information as methods acceptable to the NRC staff for implementing specific parts of the NRC's regulations, techniques used by the staff in its review of applications for permits and licenses, and data needed by the NRC staff in its review of applications for permits and licenses.

Regulatory Guide 1.195, "Methods and Assumptions for Evaluating Radiological Consequences of Design Basis Accidents at Light-Water Nuclear Power Reactors," provides guidance to licensees of operating power reactors on methods and assumptions for performing evaluations of fission product releases and radiological consequences of several postulated light-water reactor design basis accidents.

Regulatory Guide 1.196, "Control Room Habitability at Light-Water Nuclear Power Reactors," provides guidance and criteria acceptable to the NRC staff for implementing the NRC's regulations regarding control room habitability.

Regulatory Guide 1.197, "Demonstrating Control Room Envelope Integrity at Nuclear Power Reactors," provides an approach acceptable to the NRC staff for measuring inleakage into the control room and associated rooms and areas at nuclear power reactors.

Comments and suggestions in connection with items for inclusion in guides currently being developed or improvements in all published guides

are encouraged at any time. Written comments may be submitted to the Rules and Directives Branch, Division of Administrative Services, Office of Administration, U.S. Nuclear Regulatory Commission, Washington DC 20555.

Regulatory Guides are available for inspection or downloading at the NRC's Web site at <http://www.nrc.gov> under Regulatory Guides and in NRC's Electronic Reading Room (ADAMS System) at the same site. Single copies of regulatory guides may be obtained free of charge by writing the Reproduction and Distribution Services Section, U.S. Nuclear Regulatory Commission, Washington, DC 20555-0001, or by fax to (301) 415-2289, or by e-mail to distribution@nrc.gov. Issued guides may also be purchased from the National Technical Information Service on a standing order basis. Details on this service may be obtained by writing NTIS, 5285 Port Royal Road, Springfield, VA 22161. Regulatory guides are not copyrighted, and Commission approval is not required to reproduce them. (5 U.S.C. 552(a))

Dated at Rockville, MD this 29th day of May 2003.

For the Nuclear Regulatory Commission.

Ashok C. Thadani,

Director, Office of Nuclear Regulatory Research.

[FR Doc. 03-14685 Filed 6-10-03; 8:45 am]

BILLING CODE 7590-01-P

NUCLEAR REGULATORY COMMISSION

Solicitation of Public Comments on Draft NMSS Policy and Procedures Letter 1-82 and Backfit Guidance

AGENCY: Nuclear Regulatory Commission (NRC).

ACTION: Notice of opportunity for comment.

SUMMARY: The NRC's Office of Nuclear Material Safety and Safeguards (NMSS) has drafted guidance for the NRC staff on applying the backfit requirements of 10 CFR part 70 to fuel cycle facilities. The draft guidance is titled, NMSS Policy and Procedures Letter (P&PL) 1-82, "10 CFR part 70 Backfit Guidance." The P&PL is now available for stakeholder review and comment.

DATES: Written comments must be filed within 30 days of the publication of this **Federal Register** notice. Comments received after this date will be considered, however the Commission will only be able to ensure the incorporation of comments received on or before this date.