

(702) 364–3195; or by email to mark.litwin@swgas.com. Any subsequent submissions by an intervenor must be served on the applicant and all other parties to the proceeding. Contact information for parties can be downloaded from the service list at the eService link on FERC Online. Service can be via email with a link to the document.

All timely, unopposed⁷ motions to intervene are automatically granted by operation of Rule 214(c)(1).⁸ Motions to intervene that are filed after the intervention deadline are untimely, and may be denied. Any late-filed motion to intervene must show good cause for being late and must explain why the time limitation should be waived and provide justification by reference to factors set forth in Rule 214(d) of the Commission's Rules and Regulations.⁹ A person obtaining party status will be placed on the service list maintained by the Secretary of the Commission and will receive copies (paper or electronic) of all documents filed by the applicant and by all other parties.

Tracking the Proceeding

Throughout the proceeding, additional information about the project will be available from the Commission's Office of External Affairs, at (866) 208–FERC, or on the FERC website at <http://www.ferc.gov> using the “eLibrary” link as described above. The eLibrary link also provides access to the texts of all formal documents issued by the Commission, such as orders, notices, and rulemakings.

In addition, the Commission offers a free service called eSubscription which allows you to keep track of all formal issuances and submittals in specific dockets. This can reduce the amount of time you spend researching proceedings by automatically providing you with notification of these filings, document summaries, and direct links to the documents. For more information and to register, go to www.ferc.gov/docs-filing/esubscription.asp.

Intervention Deadline: 5:00 p.m. Eastern Time on May 4, 2022.

Dated: April 13, 2022.

Debbie-Anne A. Reese,
Deputy Secretary.

[FR Doc. 2022–08370 Filed 4–19–22; 8:45 am]

BILLING CODE 6717–01–P

⁷ The applicant has 15 days from the submittal of a motion to intervene to file a written objection to the intervention.

⁸ 18 CFR 385.214(c)(1).

⁹ 18 CFR 385.214(b)(3) and (d).

DEPARTMENT OF ENERGY

Federal Energy Regulatory Commission

[Docket No. NJ22–10–000]

Oncor Electric Delivery Company LLC; Notice of Filing

Take notice that on April 12, 2022, Oncor Electric Delivery Company LLC submitted its tariff filing: Tariff for Transmission Service to, from and over certain Interconnections, to be effective March 31, 2022.

Any person desiring to intervene or to protest this filing must file in accordance with Rules 211 and 214 of the Commission's Rules of Practice and Procedure (18 CFR 385.211, 385.214). Protests will be considered by the Commission in determining the appropriate action to be taken but will not serve to make protestants parties to the proceeding. Any person wishing to become a party must file a notice of intervention or motion to intervene, as appropriate. Such notices, motions, or protests must be filed on or before the comment date. On or before the comment date, it is not necessary to serve motions to intervene or protests on persons other than the Applicant.

In addition to publishing the full text of this document in the **Federal Register**, the Commission provides all interested persons an opportunity to view and/or print the contents of this document via the internet through the Commission's Home Page (<http://www.ferc.gov>) using the “eLibrary” link. Enter the docket number excluding the last three digits in the docket number field to access the document. At this time, the Commission has suspended access to the Commission's Public Reference Room, due to the proclamation declaring a National Emergency concerning the Novel Coronavirus Disease (COVID–19), issued by the President on March 13, 2020. For assistance, contact the Federal Energy Regulatory Commission at FERCOnlineSupport@ferc.gov or call toll-free, (866) 208–3676 or TTY, (202) 502–8659.

The Commission strongly encourages electronic filings of comments, protests and interventions in lieu of paper using the “eFiling” link at <http://www.ferc.gov>. Persons unable to file electronically may mail similar pleadings to the Federal Energy Regulatory Commission, 888 First Street NE, Washington, DC 20426. Hand delivered submissions in docketed proceedings should be delivered to Health and Human Services, 12225

Wilkins Avenue, Rockville, Maryland 20852.

Comment Date: 5:00 p.m. Eastern Time on May 3, 2022.

Dated: April 13, 2022.

Debbie-Anne A. Reese,
Deputy Secretary.

[FR Doc. 2022–08365 Filed 4–19–22; 8:45 am]

BILLING CODE 6717–01–P

DEPARTMENT OF ENERGY

Federal Energy Regulatory Commission

[Project No. 3025–031]

Green Mountain Power Corporation; Notice of Application Tendered for Filing With the Commission and Establishing Procedural Schedule for Licensing and Deadline for Submission of Final Amendments

Take notice that the following hydroelectric application has been filed with the Commission and is available for public inspection.

a. *Type of Application:* Subsequent Minor License.

b. *Project No.:* 3025–031.

c. *Date filed:* March 30, 2022.

d. *Applicant:* Green Mountain Power Corporation (GMP).

e. *Name of Project:* Kelley's Falls Project (project).

f. *Location:* On the Piscataquog River in Hillsborough County, New Hampshire. The project does not occupy any federal land.

g. *Filed Pursuant to:* Federal Power Act 16 U.S.C. 791(a)–825(r).

h. *Applicant Contact:* Mr. John Greenan, PE, Green Mountain Power Corporation, 2152 Post Road, Rutland, VT 05701; Phone at (802) 770–2195, or email at John.Greenan@greenmountainpower.com.

i. *FERC Contact:* Arash Barsari at (202) 502–6207, or Arash.JalaliBarsari@ferc.gov.

j. This application is not ready for environmental analysis at this time.

k. *Project Description:* The existing Kelley's Falls Project consists of: (1) An approximately 230-foot-long, 31-foot-high concrete and stone masonry dam that includes: (a) An approximately 31-foot-long stone masonry east abutment with an intake structure that includes an 11-foot-wide, 11-foot-high headgate equipped with a 22.2-foot-wide, 17-foot-high trashrack with 2.5-inch clear bar spacing; (b) a 192-foot-long concrete ogee spillway section with: (i) A 6-foot-wide, 2.75-foot-high steel slide gate that includes a 3-foot-wide, 2-foot-high notch; (ii) 2.75-foot-high flashboards;